



**Special/Study Session Meeting
6:00 p.m., Monday, September 17, 2018
Conference Room
23600 Liberty Street
Farmington, MI 48335**

STUDY SESSION AGENDA

- 1. Roll Call**
- 2. Approval of Agenda**
- 3. Public Comment**
- 4. Presentation by Matt Parks, OHM Revised State of Michigan Lead & Copper Rule**
- 5. Discussion on Road Projects**
- 6. Other Business**
- 7. Council Comment**
- 8. Adjournment**

Farmington City Council Staff Report	Council Meeting Date: September 17, 2018	Item Number 4
Submitted by: Charles Eudy, Superintendent		
Agenda Topic Presentation by Matt Parks, OHM Revised State of Michigan Lead & Copper Rule		
Proposed Motion: None		
Background: The State of Michigan has proposed to change the Lead and Copper Rule (LCR). The pending rule will be stricter than all other states. This rule will now classify galvanized water services in the same category as lead water services. <ul style="list-style-type: none"> • Water suppliers will be required to inventory all water service material types. • Water suppliers will be required to replace all known water services that are lead or galvanized in a timely manner. • Water suppliers will be required to notify property owner and replace all water services which are galvanized pipe or lead from the water main to the interior of the building. • The water supplier will be responsible for the cost of the replacement, not the property owner. • Water supplier lead and copper sampling schedule will be drastically increased. City of Farmington currently samples 6 locations every 3 years. The new schedule could require the City to sample up to 60 locations per sampling cycle. • The Action Level will be reduced from 15 parts per billion (ppb) to 12 ppb effective 2025. • Many communities object to the requirements of the revised LCR 		
Materials:		